

Issue Date: 04-25-2016  
Revision Date: 04-30-2018  
Renewal Date: 04-25-2019

**DIVISION: 07 00 00 – THERMAL AND MOISTURE PROTECTION**

**Section: 07 18 13 – Pedestrian Traffic Coatings**

**REPORT HOLDER:**

O'Sullivan® Films, Inc.  
1944 Valley Avenue  
Winchester, VA 22601  
(540) 667-6666  
[www.osul.com](http://www.osul.com)

**REPORT SUBJECT:**

*IntelliDeck™*

### 1.0 SCOPE OF EVALUATION

1.1. This research report addresses compliance with the following Codes:

- 2018, 2015 *International Building Code*® (IBC)
- 2018, 2015 *International Residential Code*® (IRC)

1.2. IntelliDeck™ has been evaluated for the following properties (see Table 1):

- Physical Properties
- Wind Resistance
- Chemical Resistance
- Fire Resistance

1.3. IntelliDeck™ has been evaluated for the following uses.

- IntelliDeck™ is a walking surface applied to a wood deck substrate
- IntelliDeck™ is a roofing surface applied to wood or non-combustible densdeck substrates. When applied to densdeck decking, IntelliDeck™ has a Class A fire resistance classification.

### 2.0 STATEMENT OF COMPLIANCE

2.1. IntelliDeck™ complies with the Codes listed in Section 1.1, for the properties stated in Section 1.2 and uses stated in Section 1.3, when installed as described in

this report, including the Conditions of Use stated in section 6.0.

### 3.0 DESCRIPTION

3.1. IntelliDeck™ is a calendered poly vinyl chloride (PVC) membrane that is laminated to a polyethylene non-woven scrim-back ply.

3.2. IntelliDeck™ is printed and embossed with a variety of patterns and colors and applied as a deck or roof covering and available in 72" wide webs.

3.3. The tri-laminate membrane weighs approximately 54 ounces per square yard and is nominally 60 mils thick.

### 4.0 PERFORMANCE CHARACTERISTICS

4.1. Wind Uplift rated at 98 psf. when installed in accordance to section 5 of this report.

### 5.0 INSTALLATION

IntelliDeck™ must be installed in accordance with the manufacturer's published installation instructions, the applicable Code and this Research Report. A copy of the manufacturer's instructions must be available on the jobsite during installation.

5.1. Substrates must be structurally sound and in accordance with applicable code. Surface shall be dry and free from all debris with installation being limited to time periods where precipitation is not expected.

5.2. Flashing shall be installed in accordance with applicable code must be applied to all door thresholds, jambs, fascia and walls.

5.3. Subsequent sheets of membrane are installed with a 1" overlap and melted together with an approved heat gun and nozzle. A seam roller is used to bond the two surfaces together.

5.4. IntelliDeck™ shall be installed with ITW Miracle Decking Adhesive.



5.5. Repairs to the membrane require that the damaged film be cut and removed. Application of the patch is as described in Section 5.4

## 6.0 CONDITIONS OF USE

6.1. Installation must comply with this Research Report, the manufacturer's published installation instructions and the applicable Code. In the event of a conflict, this report governs.

6.2. The IntelliDeck™ described in this Research Report complies with, or is a suitable alternative to, what is specified in those Codes listed in Sections 1.0 of this report, subject to the following conditions:

6.3. IntelliDeck™ installation as a walking deck is limited to a level walking surface.

6.4. IntelliDeck™ Class A roof installation is limited to non-combustible densdeck substrate with a pitch of 1/4':12 or less.

6.5. Wind uplift pressure based upon nominal wind speed ( $V_{asd}$ ) on any roof area, including edge and corner zones, must not exceed the allowable wind uplift pressure for the system installed in that particular roof area.

6.6. IntelliDeck™ is manufactured in Winchester Virginia

6.7. The Intellideck™ is manufactured under a quality program with inspections by Intertek Testing Services NA, Inc.

## 7.0 SUPPORTING EVIDENCE

7.1. Reports of tests in accordance with UL 1897-15 (-12 for 2015 and 2018 IBC), Uplift Tests for roof Covering Systems.

7.2. Fire classification testing in accordance with ASTM E108-07a (-11 and -17 for 2015 and 2018 IBC,

respectively), Standard test Methods for Fire Tests of Roof Coverings.

7.3. Data in accordance with the ICC-ES AC39, Acceptance Criteria for Walking Decks, approved June 2017.

7.4. Reports of testing in accordance with ICC-ES AC75, Acceptance Criteria for Roofing Membrane Roof-Covering Systems, revised September 2016.

## 8.0 IDENTIFICATION

The IntelliDeck™ is identified with the manufacturer's name O'Sullivan Films, Inc., address and telephone number, the product name Intellideck™, the Intertek Mark as shown below, and the Code Compliance Research Report number (CCRR-0242).



## 9.0 OTHER CODES

This section is not applicable.

## 10.0 CODE COMPLIANCE RESEARCH REPORT USE

10.1. Approval of building products and/or materials can only be granted by a building official having legal authority in the specific jurisdiction where approval is sought.

10.2. Code Compliance Research Reports shall not be used in any manner that implies an endorsement of the product by Intertek.

10.3. Reference to the Intertek website address: [whdirectory.intertek.com](http://whdirectory.intertek.com) is recommended to ascertain the current version and status of this report.

This Code Compliance Research Report ("Report") is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Report. Only the Client is authorized to permit copying or distribution of this Report and then only in its entirety, and the Client shall not use the Report in a misleading manner. Client further agrees and understands that reliance upon the Report is limited to the representations made therein. The Report is not an endorsement or recommendation for use of the subject and/or product described herein. This Report is not the Intertek Listing Report covering the subject product and utilized for Intertek Certification and this Report does not represent authorization for the use of any Intertek certification marks. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.





TABLE 1 – PROPERTIES EVALUATED

PROPERTY	IBC SECTION	IRC SECTION
Physical Properties	1504.6	R904
Wind Resistance	1504.3	Not Applicable
Chemical Resistance	Not applicable	Not Applicable
Fire Resistance	1505	R902

